


Tools Required:

- Flat head screw driver medium
- Phillips head screw driver medium



Dimensions
A: 4-7/8 "
B: 3-7/8 "



Weight: 1.54 lbs.

Notice to Installer for 23 966:


- 1. See page 2 for specific product safety warnings.
- 2. Select the desired trim ring or housing material finish by using appropriate code number as suffix.
23 966.1 - (.1) Brilliant white
23 966.2 - (.2) Stainless steel
23 966.3 - (.3) Polished aluminum
- 3. Mounts directly to wall OVER recessed single-gang junction box.
- 4. LEDs are high-quality electronic components! Please avoid touching the light output opening of the LED directly during installation.

23 966 - installation:

- 1. Remove lens from luminaire housing by unscrewing the lens counter-clockwise.
- 2. Feed luminaire wires through base of luminaire housing.
- 3. Make supply wiring and luminaire wiring connections inside the wiring box:
MAIN VOLTAGE SUPPLY WIRE TO BLACK LUMINAIRE WIRE
NEUTRAL (COMMON) SUPPLY WIRE TO WHITE LUMINAIRE WIRE
GREEN GROUND WIRE TO GREEN LUMINAIRE WIRE

Dimming (if applicable):

- DIMMING CONTROL WIRE (+) TO POSITIVE DRIVER DIM CONTROL WIRE
DIMMING CONTROL WIRE (-) TO NEGATIVE DRIVER DIM CONTROL WIRE
- 4. Mount luminaire housing directly to wall over recessed single-gang junction box.
- 5. Replace luminaire lens by screwing into luminaire housing clockwise. Make sure gasket is seated properly.



Relamping/Maintenance

Unscrew glass by turning counter-clockwise. Clean glass and luminaire using on solvent-free cleansers. Replace glass, making sure gasket is seated properly.

Accessories

Please refer to the appropriate accessory installation sheet for further instruction when applicable.

Replacement Parts

Description	Part No
Lens/Gasket	11304440RG
LED driver (120-277V)	76003
LED module (3000K)	LED-0329/830
LED module (4000K)	LED-0329/840

Lamp: 7.5W LED

Product Safety Warnings:

THIS PRODUCT MUST BE INSTALLED IN ACCORDANCE WITH THE APPLICABLE INSTALLATION CODE BY A PERSON FAMILIAR WITH THE CONSTRUCTION AND OPERATION OF THE PRODUCT AND THE HAZARDS INVOLVED. SUITABLE FOR DAMP LOCATIONS.

MIN 90°C SUPPLY CONDUCTORS.

CE PRODUIT DOIT ÊTRE INSTALLÉ SELON LE CODE D'INSTALLATION PERTINENT, PAR UNE PERSONNE QUI CONNAÎT BIEN LE PRODUIT ET SON FONCTIONNEMENT AINSI QUE LES RISQUES INHÉRENTS. CONVIENT AUX EMPLACEMENTS HUMIDES.

LES FILS D'ALIMENTATION 90°C MIN.
