Tools Required:

4mm hex key
Phillips medium screwdriver

Dimensions

A: 6-3/4 ”

B: 14-1/8 ”

C: 4 ”

D: 3-1/2 ”

Protection Class: IP44

Weight: 5.5 lbs.

Notice to Installer for 31 098:

1. See page 2 for specific product safety warnings.
2. For wall applications only.
3. Mounts directly to a standard recessed 4" octagonal wiring box (by others) using adaptor plate (provided).
4. This product must be installed in accordance with the applicable installation code by a person familiar with the construction and operation of the product and the hazards involved.
5. In conformance with UL Standard 1598, a silicone based sealant must be used between luminaire and supporting wall.

NOTE: LEDs are high-quality electronic components! Please avoid touching them directly during installation.

NOTE: To avoid fingerprints on the luminaire use enclosed protective gloves during installation. This luminaire is made of copper and is delivered with the metal's natural finish. Time and weather factors will create a natural patina on the copper.

31 098 - Installation:

1. Undo set screw at wall box and remove mounting plate.
2. Install (2) long 8-32 x 3/4" mounting screws (provided) in the back of the adapter plate as shown.
3. Attach adapter plate to wiring box using (2) 8-32 x 1/2" screws provided. Feed luminaire wires through luminaire base and adapter plate.
4. Make supply wiring connections inside the linear wiring box:

    MAIN VOLTAGE SUPPLY WIRE TO BLACK LUMINAIRE WIRE
    NEUTRAL (COMMON) SUPPLY WIRE TO WHITE LUMINAIRE WIRE
    GREEN GROUND WIRE TO GREEN LUMINAIRE WIRE

Dimming (if applicable):

    DIMMING CONTROL WIRE (+) TO POSITIVE DRIVER DIM CONTROL WIRE
    DIMMING CONTROL WIRE (-) TO NEGATIVE DRIVER DIM CONTROL WIRE

5. Place a small bead of silicone around the back side of the luminaire base that will come in contact with the finished wall (exterior applications only).
6. Attach luminaire to adaptor plate over the mounting screws using the (2) acorn nuts provided in the mounting kit. Tighten the nuts to back the screws into the wiring box and secure the plate to the box.

Figure 1 (Generic Image)

Outlet Box
(by others)

Canopy
Base Plate

Outlet Box
Screws
(by others)

Relamping/Maintenance
No relamping necessary.

Accessories
Please refer to the appropriate accessory installation sheet for further instruction when applicable.

Replacement Parts

Description	Part No
Glass	11271541
Gasket	830734
LED Module (3000K)	LED-0253/830
LED Driver (120-277V)	76023

Lamp: 3.2W LED

In the interest of product improvement, BEGA reserves the right to make technical changes without notice.

Product Safety Warnings:

THIS PRODUCT MUST BE INSTALLED IN ACCORDANCE WITH THE APPLICABLE INSTALLATION CODE BY A PERSON FAMILIAR WITH THE CONSTRUCTION AND OPERATION OF THE PRODUCT AND THE HAZARDS INVOLVED. SUITABLE FOR WET LOCATIONS.

MIN 90°C SUPPLY CONDUCTORS.

CE PRODUIT DOIT ÊTRE INSTALLÉ SELON LE CODE D'INSTALLATION PERTINENT, PAR UNE PERSONNE QUI CONNAÎT BIEN LE PRODUIT ET SON FONCTIONNEMENT AINSI QUE LES RISQUES INHÉRENTS. CONVIENT AUX EMPLACEMENTS MOUILLÉS.

LES FILS D'ALIMENTATION 90°C MIN.

In the interest of product improvement, BEGA reserves the right to make technical changes without notice.

BEGA 1000 Bega Way, Carpinteria, CA 93013 (805)684-0533 Fax (805)566-9474 www.bega-us.com © Copyright BEGA-US 2017