


1. 50 593.X WITH CEILING BOX – SEE SPECIFICATIONS
2. LUMINAIRE IS NON-IC RATED – INSULATION MUST BE AT LEAST 3” FROM LUMINAIRE.
3. CUTOUT DIAMETER $2\frac{1}{16}$ ”



SUBMITTAL APPROVAL

APPROVED BY:

DATE: _____

REV.	DATE	DESCRIPTION
------	------	-------------

This print contains confidential information which is the property of BEGA U.S. By acceptance this information, the borrower agrees that it will not be used for any other purpose other than that which is was loaned.

CAT NO.: LUMINARE#50 593.X

DRAWN: SB
DATE: 11/26/2019

FILE NAME: 50593_BEGA_SUBMITTAL.DXF

AGEB

1000 Bega Way
Carpinteria, Ca. 93013
(805) 684-0533