


BEGA

Photometric Filename: 99058K4_BEGA_IES.IES

TEST: BE_99058K4
TEST LAB: BEGA
DATE: 11/23/2016
LUMINAIRE: 99 058K4
LAMP: 11.6W LED



Characteristics


IES Classification	Type III
Longitudinal Classification	Very Short
Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	1457
Downward Total Efficiency	N.A.
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	97
Total Luminaire Watts	14.5
Ballast Factor	1.00
Upward Waste Light Ratio	0.00
Max. Cd.	904.3 (310H, 50V)
Max. Cd. (<90 Vert.)	904.3 (310H, 50V)
Max. Cd. (At 90 Deg. Vert.)	1.7 (0.1%Lum)
Max. Cd. (80 to <90 Deg. Vert.)	161.5 (11.1%Lum)
Cutoff Classification (deprecated)	N.A. (absolute)

Lum. Classification System (LCS)


LCS Zone	Lumens	%Lamp	%Lum
FL (0-30)	194.4	N.A.	13.3
FM (30-60)	790.8	N.A.	54.3
FH (60-80)	369.7	N.A.	25.4
FVH (80-90)	12.4	N.A.	0.8
BL (0-30)	13.0	N.A.	0.9
BM (30-60)	47.9	N.A.	3.3
BH (60-80)	28.2	N.A.	1.9
BVH (80-90)	0.9	N.A.	0.1
UL (90-100)	0.1	N.A.	0.0
UH (100-180)	0.0	N.A.	0.0
Total	1457.4	N.A.	100.0

BUG Rating B0-U0*-G1

*Fixture has measured rating of U1 due to testing above 90 degrees and stray light from reflection off of the fixture body. Upon visual inspection of luminaire, it has opaque sides, there is no significant uplight ($\leq 0.5\%$), and it has therefore been assigned a value of U0. Consult factory for more information



Grid Spacing = 5 ft.



In the interest of product improvement, BEGA reserves the right to make technical changes without notice.


BEGA 1000 Bega Way, Carpinteria, CA 93013 (805)684-0533 Fax (805)566-9474 www.bega-us.com © Copyright BEGA-US 2020

10/20/2020

BEGA

Photometric Filename: 99058K35_BEGA_IES.IES

TEST: BE_99058K4
TEST LAB: BEGA
DATE: 11/23/2016
LUMINAIRE: 99 058K35
LAMP: 11.6W LED



Characteristics


IES Classification	Type III
Longitudinal Classification	Very Short
Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	1428
Downward Total Efficiency	N.A.
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	102
Total Luminaire Watts	14.5
Ballast Factor	1.00
Upward Waste Light Ratio	0.00
Max. Cd.	886.214 (310H, 50V)
Max. Cd. (<90 Vert.)	886.214 (310H, 50V)
Max. Cd. (At 90 Deg. Vert.)	1.666 (0.1%Lum)
Max. Cd. (80 to <90 Deg. Vert.)	158.27 (11.1%Lum)
Cutoff Classification (deprecated)	N.A. (absolute)

Lum. Classification System (LCS)


LCS Zone	Lumens	%Lamp	%Lum
FL (0-30)	190.5	N.A.	13.3
FM (30-60)	775.0	N.A.	54.3
FH (60-80)	362.3	N.A.	25.4
FVH (80-90)	12.1	N.A.	0.8
BL (0-30)	12.47	N.A.	0.9
BM (30-60)	46.9	N.A.	3.3
BH (60-80)	27.6	N.A.	1.9
BVH (80-90)	0.9	N.A.	0.1
UL (90-100)	0.1	N.A.	0.0
UH (100-180)	0.0	N.A.	0.0
Total	1428.1	N.A.	100.0

BUG Rating B0-U0*-G1

*Fixture has measured rating of U1 due to testing above 90 degrees and stray light from reflection off of the fixture body. Upon visual inspection of luminaire, it has opaque sides, there is no significant uplight ($\leq 0.5\%$), and it has therefore been assigned a value of U0. Consult factory for more information



Grid Spacing = 5 ft.



In the interest of product improvement, BEGA reserves the right to make technical changes without notice.


BEGA 1000 Bega Way, Carpinteria, CA 93013 (805)684-0533 Fax (805)566-9474 www.bega-us.com © Copyright BEGA-US 2020

10/20/2020

BEGA

Photometric Filename: 99058K3_BEGA_IES.IES

TEST: BE_99058K4
TEST LAB: BEGA
DATE: 11/23/2016
LUMINAIRE: 99 058K3
LAMP: 11.6W LED



Characteristics


IES Classification	Type III
Longitudinal Classification	Very Short
Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	1414
Downward Total Efficiency	N.A.
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	102
Total Luminaire Watts	14.5
Ballast Factor	1.00
Upward Waste Light Ratio	0.00
Max. Cd.	877.171 (310H, 50V)
Max. Cd. (<90 Vert.)	877.171 (310H, 50V)
Max. Cd. (At 90 Deg. Vert.)	1.649 (0.1%Lum)
Max. Cd. (80 to <90 Deg. Vert.)	1586.65 (11.1%Lum)
Cutoff Classification (deprecated)	N.A. (absolute)

Lum. Classification System (LCS)


LCS Zone	Lumens	%Lamp	%Lum
FL (0-30)	188.6	N.A.	13.3
FM (30-60)	767.0	N.A.	54.3
FH (60-80)	358.6	N.A.	25.4
FVH (80-90)	12.0	N.A.	0.8
BL (0-30)	12.6	N.A.	0.9
BM (30-60)	46.5	N.A.	3.3
BH (60-80)	27.3	N.A.	1.9
BVH (80-90)	0.9	N.A.	0.1
UL (90-100)	0.1	N.A.	0.0
UH (100-180)	0.0	N.A.	0.0
Total	1428.1	N.A.	100.0

BUG Rating B0-U0*-G1

*Fixture has measured rating of U1 due to testing above 90 degrees and stray light from reflection off of the fixture body. Upon visual inspection of luminaire, it has opaque sides, there is no significant uplight ($\leq 0.5\%$), and it has therefore been assigned a value of U0. Consult factory for more information



Grid Spacing = 5 ft.



In the interest of product improvement, BEGA reserves the right to make technical changes without notice.


BEGA 1000 Bega Way, Carpinteria, CA 93013 (805)684-0533 Fax (805)566-9474 www.bega-us.com © Copyright BEGA-US 2020

10/20/2020

BEGA

Photometric Filename: 99058K27_BEGA_IES.IES

TEST: BE_99058K4
TEST LAB: BEGA
DATE: 11/23/2016
LUMINAIRE: 99 058K27
LAMP: 11.6W LED



Characteristics


IES Classification	Type III
Longitudinal Classification	Very Short
Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	1370
Downward Total Efficiency	N.A.
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	98
Total Luminaire Watts	14.5
Ballast Factor	1.00
Upward Waste Light Ratio	0.00
Max. Cd.	850.042 (310H, 50V)
Max. Cd. (<90 Vert.)	850.042 (310H, 50V)
Max. Cd. (At 90 Deg. Vert.)	1.598 (0.1%Lum)
Max. Cd. (80 to <90 Deg. Vert.)	151.81 (11.1%Lum)
Cutoff Classification (deprecated)	N.A. (absolute)

Lum. Classification System (LCS)


LCS Zone	Lumens	%Lamp	%Lum
FL (0-30)	182.8	N.A.	13.3
FM (30-60)	743.3	N.A.	54.3
FH (60-80)	347.5	N.A.	25.4
FVH (80-90)	11.6	N.A.	0.8
BL (0-30)	12.2	N.A.	0.9
BM (30-60)	45.0	N.A.	3.3
BH (60-80)	26.5	N.A.	1.9
BVH (80-90)	0.9	N.A.	0.1
UL (90-100)	0.1	N.A.	0.0
UH (100-180)	0.0	N.A.	0.0
Total	1369.9	N.A.	100.0

BUG Rating B0-U0*-G1

*Fixture has measured rating of U1 due to testing above 90 degrees and stray light from reflection off of the fixture body. Upon visual inspection of luminaire, it has opaque sides, there is no significant uplight ($\leq 0.5\%$), and it has therefore been assigned a value of U0. Consult factory for more information



Grid Spacing = 5 ft.



In the interest of product improvement, BEGA reserves the right to make technical changes without notice.


BEGA 1000 Bega Way, Carpinteria, CA 93013 (805)684-0533 Fax (805)566-9474 www.bega-us.com © Copyright BEGA-US 2020

10/20/2020

BEGA

Photometric Filename: 99058AMB_BEGA_IES.IES

TEST: L061914303
TEST LAB: Light Laboratory, Inc.
DATE: 7/2/2020
LUMINAIRE: 99 058AMB
LAMP: 17.6W LED




Characteristics


IES Classification	Type III
Longitudinal Classification	Short
Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	574
Downward Total Efficiency	N.A.
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	28
Total Luminaire Watts	20.73
Ballast Factor	1.00
Upward Waste Light Ratio	0.00
Max. Cd.	385.8 (50H, 55V)
Max. Cd. (<90 Vert.)	385.8 (50H, 55V)
Max. Cd. (At 90 Deg. Vert.)	0 (0.0%Lum)
Max. Cd. (80 to <90 Deg. Vert.)	64.32 (11.2%Lum)
Cutoff Classification (deprecated)	N.A. (absolute)

Lum. Classification System (LCS)

LCS Zone	Lumens	%Lamp	%Lum
FL (0-30)	60.1	N.A.	10.5
FM (30-60)	315.0	N.A.	54.9
FH (60-80)	162.1	N.A.	28.3
FVH(80-90)	6.0	N.A.	1.1
BL (0-30)	3.4	N.A.	0.6
BM (30-60)	16.4	N.A.	2.9
BH (60-80)	10.1	N.A.	1.8
BVH(80-90)	0.5	N.A.	0.1
UL (90-100)	0.0	N.A.	0.0
UH (100-180)	0.0	N.A.	0.0
Total	573.6	N.A.	100.0
BUG Rating	B0-U0-G0		



Grid Spacing = 5 ft.




In the interest of product improvement, BEGA reserves the right to make technical changes without notice.

BEGA

Photometric Filename:
99058K4__BEGA_AWB_IES.IES

TEST: BE_99058K4
TEST LAB: BEGA
DATE: 11/23/2016
LUMINAIRE: 99 058K4_AWB
LAMP: 17.8W LED




Characteristics

IES Classification	Type IV
Longitudinal Classification	Medium
Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	550
Downward Total Efficiency	N.A.
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	25
Total Luminaire Watts	22
Ballast Factor	1.00
Upward Waste Light Ratio	0.00
Max. Cd.	677.5 (295H, 75V)
Max. Cd. (<90 Vert.)	677.5 (295H, 75V)
Max. Cd. (At 90 Deg. Vert.)	0 (0.0%Lum)
Max. Cd. (80 to <90 Deg. Vert.)	332.3 (60.4%Lum)
Cutoff Classification (deprecated)	N.A. (absolute)


Lum. Classification System (LCS)

LCS Zone	Lumens	%Lamp	%Lum
FL (0-30)	45.8	N.A.	8.3
FM (30-60)	177.5	N.A.	32.3
FH (60-80)	275.4	N.A.	50.1
FVH (80-90)	17.1	N.A.	3.1
BL (0-30)	1.4	N.A.	0.3
BM (30-60)	6.6	N.A.	1.2
BH (60-80)	23.6	N.A.	4.3
BVH (80-90)	2.4	N.A.	0.4
UL (90-100)	0.0	N.A.	0.0
UH (100-180)	0.0	N.A.	0.0
Total	549.8	N.A.	100.0

BUG Rating B0-U0-G1



Grid Spacing = 5 ft.



In the interest of product improvement, BEGA reserves the right to make technical changes without notice.

BEGA 1000 Bega Way, Carpinteria, CA 93013 (805)684-0533 Fax (805)566-9474 www.bega-us.com © Copyright BEGA-US 2020

10/20/2020